




J / P	JACK / PLUG DESCRIPTION
2	HEAT
3	UNIT ECONOMIZER
18	EXHAUST FAN
24	EXHAUST FAN
35	TEST
43	BLOWER MOTOR
132	BLOWER , EXHAUST FAN MOTOR
250	SMOKE DETECTOR ONE
251	SMOKE DETECTOR ONE
252	SMOKE DETECTOR TWO
253	SMOKE DETECTOR TWO
255	MODULE, CONTROL SMOKE DETECTION
261	SMOKE DETECTOR JUMPER

BLOWER(G)

HEAT 1(W1)

HEAT 2(W2)

COOL 1(Y1)

KEY	COMPONENT
A6	CONTROL, SOLID STATE ENTHALPY
A171	SENSOR ONE, SMOKE, RETURN AIR
A172	SENSOR TWO, SMOKE, SUPPLY AIR
A173	MODULE, CONTROL SMOKE DETECTION
B1	COMPRESSOR
B3	MOTOR, BLOWER
B4	MOTOR, OUTDOOR FAN
B7	DAMPER MOTOR, ECONOMIZER
B10	MOTOR, EXHAUST FAN
C1	CAPACITOR, OUTDOOR FAN
C6	CAPACITOR, EXHAUST FAN
CB8	CIRCUIT, BREAKER
DL46	DELAY, OVERFLOW SWITCH
HR1	HEATER, COMPRESSOR
K1,-1	CONTACTOR, COMPRESSOR
K3,-1	CONTACTOR, BLOWER
K10,-1	RELAY, OUTDOOR FAN 1
K65,-1,2	RELAY, EXHAUST FAN
K220,-1	RELAY, OVERFLOW DELAY
S3	SWITCH, LIMIT LOW COMPRESSOR 1
S4	SWITCH, LIMIT HI PRESS (MANUAL RESET)
S5	SWITCH, LIMIT HI TEMP COMPRESSOR 1
S11	SWITCH, LOW PRESS, LOW AMBIENT KIT
S40	THERMOSTAT, CRANKCASE
S42	SWITCH, OVERLOAD RELAY BLOWER MOTOR
S49	SWITCH, FREEZEESTAT
S149	SWITCH, OVERFLOW
T1	TRANSFORMER, CONTROL
TB2	TERMINAL STRIP, UNIT

NOTE - IF ANY WIRE IN THIS APPLIANCE IS REPLACED IT MUST BE REPLACED WITH WIRE OF LIKE SIZE, RATING, TERMINATION AND INSULATION THICKNESS

WARNING - ELECTRIC SHOCK HAZARD, CAN CAUSE INJURY OR DEATH. UNIT MUST BE GROUNDED IN ACCORDANCE WITH NATIONAL AND LOCAL CODES

DISCONNECT ALL POWER BEFORE SERVICING!

NOTE - FOR USE WITH COPPER CONDUCTORS ONLY
REFER TO UNIT RATING PLATE FOR MINIMUM
CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT
PROTECTION SIZE.

J2-8,9 AND P2 ARE USED ON KCA UNITS ONLY
IMPORTANT: TO PREVENT MOTOR BURNOUT, NEVER
CONNECT MORE THAN ONE MOTOR LEAD TO ANY ONE
CONNECTION. TAPE UNUSED MOTOR LEADS

CONNECT A172 SENSOR TO J261 ON SUPPLY AIR SMOKE
DETECTOR ONLY

S20-HR1 FACTORY INSTALLED ON KCA/KGA 072,090.
HR1 (NO S40) FIELD OPTION ON KCA/KGA 036,048,060.

— DENOTES OPTIONAL COMPONENTS
— LINE VOLTAGE FIELD INSTALLED



LANDMARK
WIRING DIAGRAM

09/11

COOLING

KCA, KGA - 036,048,060, 072, 090 - M

SECTION B

REV 0

Supersedes
537296-02

New Form No.
537296-03

© 2011

Lennox Commercial