




KEY	COMPONENT
A146	CONTROL, BACNET
A194	CONTROL, REFRIGERANT LEAK DET.
J3/P3	JACK/PLUG, ECONOMIZER OR BYPASS
K253-1	RELAY, ECON FDD
TB1	TERMINAL STRIP, CLASS II VOLTAGE

- 1 BACNET CONTROL KIT REPLACES A2 (THERMOSTAT) ALONG WITH FIELD PROVIDED WIRING SHOWN BETWEEN A2 AND A194 ON UNIT WIRING DIAGRAM, B SECTION.
- 2 REFER TO UNIT DIAGRAM, B SECTION, FOR WIRING DETAILS.
- 3 ONLY USED ON UNITS WITH JADE (W7220) ECONOMIZER CONTROL.
- ← DENOTES OPTIONAL COMPONENTS
- — — CLASS II FIELD WIRING

2025/01	WIRING DIAGRAM	01/25
538608-01		
CONTROLS		
CONTROL FOR BACNET MODULE - EL_KA UNITS		
SECTION C		REV. 0
Supersedes	New Form No.	538608-01