VRF (Variable Refrigerant Flow) **User manual**

V22D***S6-5P

- Thank you for purchasing this Lennox Product.
- Before operating this unit, please read this manual carefully and retain it for future reference.





Contents

Safety Information	3
Safety Information	3
At a Glance	13
Indoor Unit Overview	13
Operation Features	14
Operating temperature and humidity	14
Pairing an indoor unit with a remote control	15
Cleaning and Maintenance	16
Cleaning and Maintaining	16
Cleaning the indoor unit exterior • Cleaning the outdoor unit heat exchanger	16
Cleaning the air filter	17
Periodical maintenance	21
Troubleshooting	22

California Proposition 65 Warning (US)

↑ WARNING:

Cancer and Reproductive Harm www.P65Warnings.ca.gov.

Before using your new air conditioner, please read this manual thoroughly to ensure that you know how to operate the extensive features and functions of your new appliance safely and efficiently.

Because the following operating instructions cover various models, the characteristics of your air conditioner may differ slightly from those described in this manual. If you have any questions, call your nearest contact center or find help and information online at www.lennox.com for homeowners and www.lennoxpros.com for dealer/contractor.

ENERGY STAR qualified model only

Proper sizing and installation of equipment is critical to achieve optimal performance. Split system air conditioners and heat pumps (excluding ductless systems) must be matched with appropriate coil components to meet ENERGY STAR criteria. Ask your contractor for details or visit www.energystar.gov.







♠ WARNING

Hazards or unsafe practices that may result in severe personal injury or death.



⚠ CAUTION

Hazards or unsafe practices that may result in minor personal injury or property damage.

- Follow directions.
- O Do NOT attempt.
- Make sure the machine is grounded to prevent electric shock.
- © Cut-off the power supply.
- Do NOT disassemble.

Symbol	Meaning
	Flammable gas
	Flammable materials
Refrigerant Safety Group AZL	Refrigerant safety group
	Read operating manual
Ţ <u>i</u>	Refer to operating manual
	Read service manual

FOR INSTALLATION



♠ WARNING



Use the power line with the power specifications of the product or higher and use the power line for this appliance only. In addition, do not use an extension line.

- Extending the power line may result in electric shock or fire.
- Do not use an electric transformer. This may result in electric shock or fire.
- If the voltage/frequency/rated current condition is different, it may cause fire.

The installation of this appliance must be performed by a qualified technician or service company.

• Failing to do so may result in electric shock, fire, explosion, problems with the product, or injury.

Install a switch and circuit breaker dedicated to the air conditioner.

• Failing to do so may result in electric shock or fire.

Fix the outdoor unit firmly so that the electric part of the outdoor unit is not exposed.

• Failing to do so may result in electric shock or fire.

This product is equipped with a safety device that operates on electricity.

• To ensure normal operation of the safety device, power must be supplied to the product at all times after installation, except when repairing it.

- This product is equipped with a refrigerant leak sensor for the purpose of safety.
 - To ensure normal operation of the refrigerant leak sensor, power must be supplied to the product at all times after installation, except when repairing it.
- On not install this appliance near a heater, inflammable material. Do not install this appliance in a humid, oily or dusty location, in a location exposed to direct sunlight and water (rain drops). Do not install this appliance in a location where gas may leak.
 - This may result in electric shock or fire. Never install the outdoor unit in a location such as on a high external wall where it could fall.
 - If the outdoor unit falls, it may result in injury, death or property damage.
- This appliance must be properly grounded. Do not ground the appliance to a gas pipe, plastic water pipe, or telephone line.
 - Failure to do so may result in electric shock, fire, an explosion, or other problems with the product.
 - Make sure that it is in accordance with local and national codes.

⚠ CAUTION

- Install your appliance on a level and hard floor that can support its weight.
 - Failing to do so may result in abnormal vibrations, noise, or problems with the product.

Install the drain hose properly so that water is drained correctly.

• Failing to do so may result in water overflowing and property damage. Avoid adding drain to waste pipes as odours may arise in the future.

- When installing the outdoor unit, make sure to connect the drain hose so that draining is performed correctly.
 - The water generated during the heating operation in the outdoor unit may overflow and result in property damage. In particular, in winter, if a block of ice falls, it may result in injury, death or property damage.

The product shall be stored in a room with no ignition sources (e.g. open flames, gas appliance, electric heater, etc.).

• Note that the refrigerant has no odor.

FOR POWER SUPPLY

⚠ WARNING

- When the circuit breaker is damaged, contact your nearest service center.
- O Do not pull or excessively bend the power line. Do not twist or tie the power line. Do not hook the power line over a metal object, place a heavy object on the power line, insert the power line between objects, or push the power line into the space behind the appliance.
 - This may result in electric shock or fire.

↑ CAUTION

- When not using the air conditioner for a long time or during a thunder/lightning storm, cut the power at the circuit breaker.
 - Failing to do so may result in electric shock or fire.

FOR USING



⚠ WARNING



If the appliance is flooded, please contact your nearest service center.

• Failing to do so may result in electric shock or fire.

If the appliance generates a strange noise, a burning smell or smoke, cut-off the power supply immediately and contact the nearest service center.

• Failing to do so may result in electric shock or fire.

In the event of a gas leak (such as propane gas, LP gas, etc.), ventilate immediately without touching the power line. Do not touch the appliance or power line.

- Do not use a ventilating fan.
- A spark may result in an explosion or fire.

To reinstall the air conditioner, please contact your nearest service center.

- Failing to do so may result in problems with the product, water leakage, electric shock, or fire.
- A delivery service for the product is not provided. If you reinstall the product in another location, additional construction expenses and an installation fee will be charged.
- Especially, when you wish to install the product in an unusual location such as in an industrial area or near the seaside where it is exposed to salt in the air, please contact your nearest service center
- O Do not touch the circuit breaker with wet hands.
 - This may result in electric shock.

- O not turn the air conditioner off with the circuit breaker while it is operating.
 - Turning the air conditioner off and then on again with the circuit breaker may cause a spark and result in electric shock or fire.

After unpacking the air conditioner, keep all packaging materials well out of the reach of children, as packaging materials can be dangerous to children.

• If a child places a bag over its head, it may result in suffocation. Do not touch the front panel with your hands or fingers during the heating operation.

• This may result in electric shock or burns.

Do not insert your fingers or foreign substances into the outlet when the air conditioner is operating or the front panel is closing.

• Take special care that children do not injure themselves by inserting their fingers into the product.

Do not insert your fingers or foreign substances into the air inlet/outlet of the air conditioner.

• Take special care that children do not injure themselves by inserting their fingers into the product.

Do not strike or pull the air conditioner with excessive force.

• This may result in fire, injury, or problems with the product.

Do not place an object near the outdoor unit that allows children to climb onto the machine.

• This may result in children seriously injuring themselves.

Do not use this air conditioner for long periods of time in badly ventilated locations or near infirm people.

• Since this may be dangerous due to a lack of oxygen, open a window at least once an hour.



- If any foreign substance such as water has entered the appliance, cut-off the power supply and contact the nearest service center.
 - Failing to do so may result in electric shock or fire.
- Do not attempt to repair, disassemble, or modify the appliance vourself.
 - Do not use any fuse (such as copper, steel wire, etc.) other than the standard fuse
 - Failing to do so may result in electric shock, fire, problems with the product, or injury.

↑ CAUTION



- Do not place objects or devices under the indoor unit.
 - Water dripping from the indoor unit may result in fire or property damage.

Check that the installation frame of the outdoor unit is not broken at least once a year.

• Failing to do so may result in injury, death or property damage.

When the air conditioner does not operate properly for cooling or heating, there is a possibility of refrigerant leakage. If any leakage, stop operation, ventilate the room, and consult your dealer to recharge the refrigerant.

The refrigerant is not harmful. However, if it comes in contact with fire, it may generate harmful gases and there is a risk of fire.

During the transportation of the indoor unit, the pipelines shall be covered with brackets for protection. Do not move the product by holding the refrigerant or drain pipe connections.

• It may cause gas leakage.

Do not install the product on a ship or a vehicle (such as a campervan).

• Salt, vibration or other environmental factors may cause the product to malfunction, electric shock or fire.

- O not stand on top of the appliance or place objects (such as laundry, lighted candles, lighted cigarettes, dishes, chemicals, metal objects, etc.) on the appliance.
 - This may result in electric shock, fire, problems with the product, or injury.

Do not operate the appliance with wet hands.

• This may result in electric shock.

Do not spray volatile material such as insecticide onto the surface of the appliance.

• As well as being harmful to humans, it may also result in electric shock, fire or problems with the product.

Do not drink the water from the air conditioner.

• The water may be harmful to humans.

Do not apply a strong impact to the remote controller and do not disassemble the remote controller.

Do not touch the pipes connected with the product.

• This may result in burns or injury.

Do not use this air conditioner to preserve precision equipment, food, animals, plants or cosmetics, or for any other unusual purposes.

• This may result in property damage.

Avoid directly exposing humans, animals or plants to the air flow from the air conditioner for long periods of time.

• This may result in harm to humans, animals or plants.

This appliance is not intended for use by persons (including children) with reduced physical, sensory or mental capabilities, or lack of experience and knowledge, unless they have been given supervision or instruction concerning use of the appliance by a person responsible for their safety. Children should be supervised to ensure that they do not play with the appliance.

FOR CLEANING



↑ WARNING

- O Do not clean the appliance by spraying water directly onto it. Do not use benzene, thinner, alcohol or acetone to clean the appliance.
 - This may result in discoloration, deformation, damage, electric shock or fire.

Before cleaning or performing maintenance, cut-off the power supply and wait until the fan stops.


• Failing to do so may result in electric shock or fire.



- Take care when cleaning the surface of the heat exchanger of the outdoor unit since it has sharp edges.
 - To avoid cutting your fingers, wear thick cotton gloves when cleaning it.
 - This should be done by a qualified technician please contact your installer or service center.
- O Do not clean the inside of the air conditioner by yourself.
 - For cleaning inside the appliance, contact your nearest service center.
 - When cleaning the internal filter, refer to the descriptions in the 'Cleaning and Maintaining' section.
 - Failure to do may result in damage, electric shock or fire.
 - Make sure to prevent any injury from sharp edges of the surface when handling the heat exchanger.


Indoor Unit Overview

The indoor unit and its display may look slightly different from the illustration shown below, depending on the model and the panel type.



Indication

01 Display



O2 Air flow blade/Air outlet (inside) / WindFree panel (You can use the WindFree Cooling function when the Cool, Dry, or Fan mode is running.) (Refer to the remote control manual for product operation.)

	On/Off operation indicator
*	Removing frost indicator
Ü	Timer indicator
	Filter cleaning indicator
\bigcirc	Remote control sensor

Function

03 Air intake

04 Air filter (under the grille)

Operation Features

Operating temperature and humidity

When using the air conditioner follow the operating temperature and humidity ranges.

Mode	Indoor temperature	Outdoor temperature	Indoor humidity
Cool mode	64 °F ~ 90 °F		
Dry mode	(18~32 °C)	Depending on the outdoor unit specification	80% or less
Heat mode	86 °F (30 °C) or less		

∴ CAUTION

- If you use the air conditioner at a relative humidity above 80%, it may cause a formation of condensation and a leakage of water on the floor.
- The rated heating capacity is based on an outdoor temperature of 47°F (8°C). If the outdoor temperature goes down below 32°F (0°C), heating efficiencies may decrease depending on the temperature conditions.
- If the indoor unit is out of the operating temperature and humidity range, the safety device may operate and the air conditioner may stop.
- If the indoor unit is installed in an IT room (for example, a computer room), a separate backup system must
 be installed, and the reliability of our product cannot be guaranteed at temperatures outside the operating
 temperature range.


Pairing an indoor unit with a remote control

Use the Zone function to assign numbers to multiple indoor units installed in the same space, and control individual indoor units.



NOTE


- You can select either one or all of Zone 1 to Zone 4.
- If multiple products are in use, you can pair each indoor unit and remote control, and control indoor units individually.
- Setting a channel to individually control products
 Configure this setting using the remote control when the indoor unit power is off.



- Press the (< output >) button, and within 60 seconds, press the (Mode) button.
- The current Zone function settings persist even if you change the current mode or you turn off and then turn on the remote control.
 - If the remote control battery discharges, all settings are reset, in which case settings should be configured again.

A Before cleaning the indoor unit, be sure to turn off the auxiliary power switch.

Cleaning the indoor unit exterior



Wipe the surface of the unit with a slightly wet or dry cloth when needed. Wipe off dirt of odd-shaped areas by using a soft brush.

↑ CAUTION

- Do not use alkaline detergent, sulphuric acid, hydrochloric acid, or organic solvents (such as thinner, kerosene, and acetone) to clean the surfaces
- Do not attach any stickers on the surfaces because this may cause damage.
- When you clean the heat exchanger on the indoor unit, you need to disassemble the indoor unit. Therefore, you must contact the local service center for help.

Cleaning the outdoor unit heat exchanger



↑ CAUTION

 The heat exchanger of the outdoor unit has sharp edges. Take care when cleaning its surface.


NOTE

 If it is difficult to clean the heat exchanger of the outdoor unit, contact the local service center.

Cleaning the air filter

↑ CAUTION


- Be sure to hold the grille with a hand to prevent dropping from the opening of the front grille.
- 1 Detaching the air filter



Push down the hooks at each side of the front grille to open the grille.




• The hooks are located on both sides of the front grill with the Lennox logo.



Pull out the air filter from the indoor unit.


2 Cleaning the air filter



Clean the air filter with a vacuum cleaner or soft brush. If dust is too heavy, then rinse it with running water and dry it in a ventilated area.

∴ CAUTION


Do not scrub the air filter with a brush or other cleaning utensil. This may damage the filter.




NOTE

- If the air filter dries in a humid area, it may produce offensive odours. Clean it again and dry it in a wellventilated area.
- The cleaning period may differ depending on the usage and environmental conditions, so clean the air filter every week if the indoor unit is in the dusty area.

3 Reassembling the air filter








⚠ CAUTION

• If the indoor unit is used without the air filter, the indoor unit may be damaged due to dust.

4 Resetting the filter-cleaning reminder Programmable Wired Controller









After cleaning and reassembling the air filter, be sure to reset the filter-cleaning reminder as follows :

- Indoor unit with the wired remote control:
 - a. Press the 🕄 button to display the **Option** menu.
 - b. Press the) button to select **Filter Reset** and press the **OK** button.
 - c. Press the > button to select Indoor and press the OK button to display Filter using time.
 - d. Press the **OK** button to reset the air filter.

Wireless Remote Control



• Indoor unit with the wireless remote control:



∴ CAUTION

- The filter reset indicator blinks when the air filter should be cleaned.
- Although the filter cleaning indicator () does not light, be sure to set the "Filter Reset" after cleaning the air filter.
- If the angle of the airflow blade is changed by opening the front grille for installation or maintenance of the indoor unit, be sure to turn off and then on the auxiliary switch before operating the indoor unit again. If not, the angle of the air flow blade may change and the blades may not be closed after turning off the indoor unit.

Periodical maintenance

Unit	Maintenance item	Interval	Requires qualified technicians
	Clean the air filter.	At least once a month	
	Clean the condensate drain pan.	Once a year	Required
Indoor unit	Clean the heat exchanger.	Once a year	Required
	Clean the condensate drain pipe.	Once every 4 months	Required
	Replace R-32 detecting sensor	10 years	Required
	Clean the heat exchanger on the outside of the unit.	Once every 4 months	Required
	Clean the heat exchanger on the inside of the unit.	Once a year	Required
	Clean the electric components with jets of air.	Once a year	Required
Outdoor unit	Verify that all the electric components are firmly tightened.	Once a year	Required
	Clean the fan.	Once a year	Required
	Verify that the fan assemblies are firmly tightened.	Once a year	Required
	Clean the condensate drain pan.	Once a year	Required

NOTE

- The checks and maintenance operations described above are essential to guarantee the efficiency of the
 air conditioner. The frequency of these operations may vary depending on the characteristics of the area,
 the amount of dust, etc.
- 1 The above mentioned operations should be performed more frequently if the area of installation is very dusty.
- 2 In some cases, if the period of use of the R-32 detecting sensor exceeds 5 years, "E695" is displayed on the wired remote control. The product works normally.
 - Six months before the expiration of the period of use date, "E699" is displayed on the wired remote control, and the product operates normally.
 - If the period of use date exceeds 10 years, the wired remote control displays "E700", and the use of the product is restricted.
 - It must be replaced through Lennox Service Center before the expiration of the period of use date.
- 3 This refrigerant sensor shall only be replaced with manufacturer approved sensor these operations must always be performed by qualified personnel. For more detailed information, refer to Installation Manual.

Troubleshooting

Refer to the following chart if the air conditioner operates abnormally. This may save time and unnecessary expense.

Problem	Solution		
The product does not	Connect an R-32-capable wired remote control.		
work.	* VSTAT04P-1		
Error E694	* R-32-capable wired remote controls should be purchased separately.		
An alarm sounds, and the product does not work. Error E696	 This is intended to determine whether there is a leak or not, as R-32 refrigerant is sensed. The indoor unit determines again whether or not there is a refrigerant leak while operating for 2 minutes using fan mode (specifically High mode). If there is no refrigerant leak, the indoor unit stops operating, the error is cleared and the product can operate normally. The R-32 sensor, embedded in the indoor unit, reacts not only to R-32 refrigerant but also to high-concentration chemicals (e.g. organic solvents, hair spray and paint). Do not use any high-concentration chemicals in the vicinity of the indoor unit, as these may cause false operation of the sensor. 		
An alarm sounds, and the product does not work. Error E697, E797			

Problem	Solution
The product does not work. Error E116, E698, E699, E700	 This error occurs when the R-32 refrigerant sensor has a malfunction or the sensor's life has expired. Display 'E116' or 'E698' when a sensor failure occurs The R-32 sensor's lifespan is 10 years. The wired remote control displays 'E699' 6 months before the sensor's lifespan expires. After the sensor's lifespan expires, the wired remote control displays 'E700', and the product usage is limited. Contact the Lennox service center for assistance.
The air conditioner does not operate immediately after it has been restarted.	Because of the protective mechanism, the appliance does not start operating immediately to keep the unit from overloading. The air conditioner will start in 3 minutes.
The air conditioner does not operate at all.	 Check if the power plug is properly connected. Check whether the auxiliary power switch (MCCB, ELB) is turned on. If the auxiliary power switch (MCCB, ELB) is turned off, the air conditioner does not work although you press the (Power) button. When you clean the air conditioner, turn off the auxiliary power switch (MCCB, ELB). After the air conditioner is not used for an extended period of time, be sure to turn on the auxiliary power switch (MCCB, ELB) 6 hours before starting operation. NOTE The auxiliary power switch (MCCB, ELB) is sold separately. Make sure that auxiliary power switch (MCCB, ELB) is installed in the distribution box inside the building. If the air conditioner is turned off by the Timed off function, turn on the air conditioner again by pressing the (Power) button.
The temperature does not change.	Check whether the Fan mode is running. In the Fan mode, the air conditioner controls the set temperature automatically, and you cannot change the set temperature.
Warm air does not come out of the air conditioner.	 Check whether the outdoor unit is designed for cooling only. In this case, warm air does not come out although you select the Heat mode. Check whether the remote control is designed only for cooling only. Use a remote control that supports both cooling and heating.

Problem	Solution
The fan speed does not change.	Check whether the Auto or Dry mode is running. In these modes, the air conditioner controls the fan speed automatically, and you cannot change the fan speed.
The wireless remote control does not operate.	 Check whether the wireless controller is charged. Charge the controller if needed. Make sure that nothing is blocking the remote control sensor. Check whether any strong lighting sources are near the air conditioner. Strong light which comes from fluorescent bulbs or neon signs may interfere with the remote control.
The wired remote control does not operate.	Check whether the
The air conditioner is not turned on or off immediately with the wired remote control.	Check whether the wired remote control is set for group control. In this case, the air conditioners connected to the wired remote control are turned on or off sequentially. This operation takes up to 32 seconds.
The Timed on/off function does not operate.	Check whether you pressed the (SET) button on the remote control after setting the on/off time. Set the on/off time.
The indoor unit display blinks continuously.	 Turn on the air conditioner again by pressing the ((Power) button. Turn off and then turn on the auxiliary power switch, and then turn on the conditioner. If the indoor unit display is still blinking, contact a service center.
I want to get cooler air.	Operate the air conditioner with a electric fan to save energy and enhance the cooling efficiency.

Problem	Solution	
The air is not cool or warm enough.	 In the Cool mode, cool air does not come out if the set temperature is higher than the current temperature. Remote control: Press the Temperature button repeatedly until the set temperature [minimum: 64°F (18°C)] is set to lower than the current temperature. In the Heat mode, warm air does not come out if the set temperature is lower than the current temperature. Remote control: Press the Temperature button repeatedly until the set temperature [maximum: 86°F (30°C)] is set to higher than the current temperature. Both cooling and heating do not operate in the Fan mode. Select the Cool, Heat, Auto, or Dry mode. Check whether the air filter is blocked with dirt. A dusty filter may decrease the cooling and heating efficiencies. Clean the air filter frequently. If a cover is on the outdoor unit or any obstacle is present near the outdoor unit, remove them. 	
	 Install the outdoor unit in a well-ventilated place. Avoiding places exposed to direct sunlight or close to a heating appliance. Place a sunscreen over the outdoor unit to protect it from direct sunlight. If the indoor unit is installed in a place exposed to direct sunlight, pull the curtains on the windows. 	
The air is not cool or warm enough.	 Close the windows and doors to maximize the cooling and heating efficiencies. If the Cool mode is stopped and then started immediately, cool air comes out after about 3 minutes to protect the compressor of the outdoor unit. When the Heat mode is started, warm air does not come out immediately to prevent cool air from coming out at the beginning. If the refrigerant pipe is too long, the cooling and heating efficiencies may be decreased. Avoid exceeding the maximum pipe length. 	
The air conditioner makes strange noises.	 In certain conditions [especially, when the outdoor temperature is lower than 68°F (20°C)], a hissing, rumbling, or splashing sound may be heard while the refrigerant is circulating through the air conditioner. This is a normal operation. When you press the (b) (Power) button on the remote control, noise may be heard from the drain pump inside the air conditioner. This noise is a normal sound. 	

Problem	Solution	
Unpleasant odours permeate the room.	 If the air conditioner is running in a smoky area or if there is a smell entering from outside, ventilate the room properly. If both indoor temperature and indoor humidity are high, operate the air conditioner in the Clean or Fan mode for 1 to 2 hours. If the air conditioner has not been operated for an extended period of time, clean the indoor unit and then operate the air conditioner in the Fan mode for 3 to 4 hours to dry the inside of the indoor unit for removal of unpleasant odours. 	
	If the air filter blocked with dirt, clean the air filter.	
Steam is produced on the indoor unit.	 In winter, if the indoor humidity is high, steam may be produced around the air outlet while the defrost function is running. This is a normal operation. 	
The outdoor unit fan continues to operate when the air conditioner is turned off.	W hen the air conditioner is turned off, the outdoor unit fan may continue to operate to reduce noise of the refrigerant gas. This is a normal operation.	
Water drops from the piping connections of the outdoor unit.	Condensation may develop due to the difference in temperature. This is a normal condition.	
Steam is produced on the outdoor unit.	In winter, when the air conditioner runs in the Heat mode, the frost on the heat exchanger melts and steam may be produced. This is a normal operation, neither product malfunction nor a fire.	



Visit us at www.lennox.com
For the latest technical information, www.lennoxcommercial.com
Contact us at 1-800-4-LENNOX

COUNTRY	CALL	OR VISIT US ONLINE AT
AMEDICA	800-953-6669	www.lennox.com for homeowners,
AMERICA		www.lennoxpros.com for dealer/contractor