

# SUBMITTAL DATA - INDOOR UNIT VHIC030S4-4P High-Static Ducted

	For:	Reference	Approval	Review	Construction
System Designation:	Date:				
Schedule No.:	Locati	on:			
Location:	Archite	ect:			
Job:	Engine	eer:			

# **High-Static Concealed Ducted Indoor Unit**

### **FEATURES**

 Built-in condensate pump

- Smart presure control system
- · Convenient installation
- Refrigerant R-410A
- Five capacity sizes from 24,000 to 48,000 Btu/h

#### WARRANTY

• 10-year limited warranty.\*See warranty for details.

SPECIFICATIONS						
PERFORMANCE						
Cooling Capacity <sup>1</sup> (Btu/h)	30,000					
Heating Capacity <sup>1</sup> (Btu/h)	34,000					
Airflow (CFM)	Low/Medium/High	583/812/989				
External Static Pressure (in. w.g.	0.12~0.79					
Sound (dBA)	Low/Medium/High	30/34/38				
ELECTRICAL DATA						
Power Supply (Volts/Hertz/Phase	208-230/60/1					
Minimum Circuit Ampacity (MCA) (A)		2.95				
Maximum Overcurrent Protection (MOP) (A)		15				
Cooling Power Input <sup>2</sup> (W)		140				
Cooling Rated Current (A)		1.2				
Heating Power Input <sup>2</sup> (W)		140				
Heating Rated Current (A)	1.2					
Fan Motor Output x n (W)		153 x 1				
DIMENSIONS						
Unit Dimensions (in) Width		51-3/16				
	Height	11-13/16				
	Depth	27-9/16				
Liquid Pipe Connection (in) (I.D)	3/8					
Gas Pipe Connection (in) (I.D.)	5/8					
Net Weight (lb)		98.1				
Shipping Weight (lb)		111.3				


OPTIONAL ACCESSORIES				
VSTAT02P-1 Touch Screen Wired Controller	37P79			
VSTAT04P-1 Individual Wired Controller	37Y74			
VSTAT01P-1 Wireless Remote Controller	37Y73			
V1FBX02-4P, VHI024-030 & VMD018 Filter Box	38B56			



### **NOTES**

- Specification may be subject to change without prior notice.
- 2. Mode: HP(Heat Pump), HR(Heat Recovery)
- Capacities are based on (Equivalent refrigerant piping 25ft, Level differences 0ft);
  - Cooling : Indoor temperature 80°F DB, 67°F WB / Outdoor temperature 95°F DB, 75°F WB Heating : Indoor temperature 70°F DB, 60°F WB / Outdoor temperature 47°F DB, 43°F WB
- Sound pressure level is a relative value, depending on the distance and acoustic environment. Sound values are obtained in an anechoic room.
- 5. Select wire size based on the value of MCA.





No.	Name -	Description		
140.		VMDC018S4-4P	VHIC024/027/030S4-4P	
1	Refrigerant liquid pipe	Ø6.35 [1/4"] Flare connection	Ø9.52 [3/8"] Flare connection	
2	Refrigerant gas pipe	Ø12.7 [1/2"] Flare connection	Ø15.88 [5/8"] Flare connection	
3	Condensate drain	Nominal Size 3/4" (OD Φ1.05" (26.67 mm))	Nominal Size 3/4" (OD Φ1.05" (26.67 mm))	
4	Power & Comm. wiring conduits	-	-	
5	Supply air flange	-	-	
6	Return air flange	-	-	
7	Hook	-	-	