



090	5 10 15 20 25 35	HE1 5 10 15 20 25 35	HE2	HE3
180	10 20 30 50	5 10 15 25	5 10 15	25

- A S149 SWITCH AND K220 RELAY MAY BE FIELD SUPPLIED OR USE AVAILABLE KIT
- △ S50 USED ON TWIN REFRIGERANT UNITS
- ↑ "M" VOLTAGE UNITS ONLY
- TB3 IS USED ON SOME UNITS
- TB2,S48 OR CB10 MAY BE USED

\_\_\_\_\_ DENOTES OPTIONAL COMPONENTS

DESCRIPTION			
KEY	COMPONENT		
	SWITCH-LIMIT,PRIMARY,ELECT HT		
S20	SWITCH-LIMIT,SECONDARY ELECT HT		
	OVERLOAD-RELAY,BLOWER MTR		
S49	SWITCH-FREEZESTAT COMPRESSOR 1		
	SWITCH-FREEZESTAT COMPRESSOR 2		
S149	SWITCH-OVERFLOW		
TB1	TERMINAL STRIP-CLASS II VOLT		
	TERMINAL STRIP-UNIT		
TB3	TERMINAL STRIP-ELECTRIC HEAT		

=					
\$21.4923	WIRING DIAGRAM	3/09			
HEATING-ELECTRIC					
EHA-G,J,M FOR USE WITH					
TAA 072-240 UNITS					
SECTION B2					
Supersedes Form No.	New Form No.				
	535,770W				
© 2009	Lit	ho U.S.A.			