

507917-03
6/2024
Supersedes 4/2024

LOW AMBIENT KIT

**INSTALLATION INSTRUCTIONS FOR LOW AMBIENT KIT (23V26; 619589-10)
USED ON KGC/KCC300 PACKAGED ROOFTOP UNITS**

Shipping and Packing List**Package 1 of 1 contains:**

- 2- Head pressure control (A190)
- 1- Temperature switch bracket
- 1- Wiring harness - A190 to K254
- 1- Wiring harness - A190 to K255
- 1- Bag assembly containing:
 - 2-Pressure transducers (A188, A189)
 - 2-Temperature switches (S201, S202)
 - 10-Wire ties
 - 1-Wiring diagram
 - 2-Screws, #8-32 X 1/2 TFS
 - 2-Screws, #8-32 X 1-1/4 TFS

⚠ CAUTION

As with any mechanical equipment, contact with sharp sheet metal edges can result in personal injury. Take care while handling this equipment and wear gloves and protective clothing.

Application

This kit allows low ambient operation to 0°F (-17.8°C) unless otherwise noted in product specifications.

Operation

When ambient temperature drops below 55°F (adjustable), S201 and S202 temperature switches open to de-energize K10 and K150 relay coils. Condenser fans 1, 2, 4 & 5 are de-energized.

Liquid line pressure transducer A188 and A189 convert the pressure to an analog signal which is sent to the head pressure controls (A190, A191). The head pressure control provides a variable output which slows Condenser Fan 3 & 6 operation at lower ambient temperatures.

⚠ WARNING

Improper installation, adjustment, alteration, service or maintenance can cause property damage, personal injury or loss of life. Installation and service must be performed by a licensed professional installer (or equivalent), service agency or the gas supplier.

Installation

- 1 - Disconnect all power to unit and open access panels.
- 2 - Install head pressure controls (A190 & A191) in the control section as shown in FIGURE 1. Secure with screws (provided).
- 3 - Install the temperature switch mounting bracket onto the mullion. Align the bracket with the 4th screw from the top of the unit; secure with provided screw. See FIGURE 1.
- 4 - Install the temperature switches onto the bracket.
- 5 - Using the ICM Omni App, set the head pressure controller as follows:
 - Probe Type: Pressure
 - Setpoint: 355 psig
 - Hard Start: 0.1s
 - Minimum Voltage Output: 32%
- 6 - Install the pressure transducers on compressor 2 (stg. 2) and compressor 4 (stg. 4). liquid line pressure tap as shown in FIGURE 2.

⚠ WARNING

To prevent serious injury or death:

- 1- Lock-out/tag-out before performing maintenance.
- 2- If system power is required (e.g., smoke detector maintenance), disable power to blower, remove fan belt where applicable, and ensure all controllers and thermostats are set to the "OFF" position before performing maintenance.
- 3- Always keep hands, hair, clothing, jewelry, tools, etc., away from moving parts.

HEAD PRESSURE CONTROL AND TEMPERATURE SWITCH LOCATION




FIGURE 1

LIQUID LINE PRESSURE TAP LOCATION




FIGURE 2




FIGURE 3

Temperature Switch Wire Connections

- 1 - Route temperature switch wires through the division panel between the compressor and outdoor coil sections. See FIGURE 2.
- 2 - Disconnect male and female terminals from wires marked "S201" and "S202" near K10 relay. See FIGURE 3.
- 3 - Make wiring connections as shown in FIGURE 4.




FIGURE 4

Low Voltage Wire Connections

Use the pressure transducer, provided in this kit, to make wire connections as shown in figure 5.


High Voltage Wire Connections

Note - K254 and K255 relay location is different for reheat units as shown in figure 1.

- 1 - Connect the harness wire labeled "A190-L1" to the terminal marked "Line 1" on the A190 control.
- 2 - Connect wires labeled "A190-M" & "A191-M" to the terminal marked "Motor 2" on ICM controllers A190 & A191 as shown in FIGURE 6.
- 3 - Connect wires labeled "A190-L2" & "A191-L2" to the terminal marked "Line 2" on ICM controllers A190 & A191 as shown in FIGURE 6.
- 4 - Disconnect factory wires to K254 terminals 4 & 6. Reconnect these wires to the kit harness as shown in FIGURE 6.
- 5 - Disconnect factory wires to K255 terminals 4 & 6. Reconnect these wires to the kit harness as shown in FIGURE 6.
- 6 - Make the rest of the K254 and K255 harness connections as shown in FIGURE 6. Refer to the diagram in FIGURE 7.
- 7 - Make sure all connections are secure.
- 8 - Bundle wiring and use wire ties to route wiring away from sharp edges.
- 9 - Place the wiring diagram provided in this kit on the inside of the control door.
- 10 - Close unit panels and restore power.

PRESSURE TRANSDUCER WIRING


**A190
HEAD PRESSURE CONTROL**



**A188
STG 1
PRESSURE
TRANSDUCER**



**A191
HEAD PRESSURE CONTROL**



**A189
STG 2
PRESSURE
TRANSDUCER**



FIGURE 5

Kit Harness — — —

K254 & K255 HARNESS WIRING





FIGURE 6


24V POWER

10 X 8 INCHES

24V POWER

24V COMMON

24V COMMON



KEY	COMPONENT
A188	PRESSURE TRANSDUCER, COMP 2
A189	PRESSURE TRANSDUCER, COMP 4
A190	PRESSURE CONTROLLER, COMP 2, LOW AMBIENT KIT
A191	PRESSURE CONTROLLER, COMP 4, LOW AMBIENT KIT
B1	COMPRESSOR 1
B2	COMPRESSOR 2
B4	MOTOR, OUTDOOR FAN 1
B5	MOTOR, OUTDOOR FAN 2
B13	COMPRESSOR 3
B20	COMPRESSOR 4
B21	MOTOR, OUTDOOR FAN 3
B22	MOTOR, OUTDOOR FAN 4
B23	MOTOR, OUTDOOR FAN 5
B24	MOTOR, OUTDOOR FAN 6
C1	CAPACITOR, OUTDOOR FAN 1
C2	CAPACITOR, OUTDOOR FAN 2
C18	CAPACITOR, OUTDOOR FAN 3
C19	CAPACITOR, OUTDOOR FAN 4
C20	CAPACITOR, OUTDOOR FAN 5
C21	CAPACITOR, OUTDOOR FAN 6
J/P 35	JACK/ PLUG, RUN TEST
J/P 36	JACK/ PLUG, RUN TEST OD FANS
HR1	HEATER, COMPRESSOR 1
HR2	HEATER, COMPRESSOR 2
HR5	HEATER, COMPRESSOR 3
HR11	HEATER, COMPRESSOR 4
K1,-1,2	CONTACTOR, COMPRESSOR 1
K2,-1,2	CONTACTOR, COMPRESSOR 2
K10,-1,2	RELAY, OUTDOOR FANS 1, 2
K14,-1,2	CONTACTOR, COMPRESSOR 3
K66,-1	RELAY, STAGE COOL 1
K67,-1	RELAY, STAGE COOL 2
K146,-1,2	CONTACTOR, COMPRESSOR 4
K150,-1,2	RELAY, OUTDOOR FANS 4, 5
K254	RELAY, LOW AMBIENT KIT FAN 3
K255	RELAY, LOW AMBIENT KIT FAN 6

S4	SWITCH, LIMIT HI PRESS COMP 1
S7	SWITCH, LIMIT HI PRESS COMP 2
S28	SWITCH, LIMIT HI PRESS COMP 3
S49	SWITCH, FREEZESTAT COMP 1
S50	SWITCH, FREEZESTAT COMP 2
S95	SWITCH, FREEZESTAT COMP 4
S96	SWITCH, LIMIT HI PRESS COMP 4
S201	SWITCH, LOW AMBIENT TEMP SENSOR 1
S202	SWITCH, LOW AMBIENT TEMP SENSOR 2
TB1	TERMINAL STRIP, 24V
TB13	TERMINAL STRIP, POWER DISTRIBUTION

- ⚠ REFER TO UNIT RATING PLATE FOR MINIMUM CIRCUIT AMPACITY AND MAXIMUM OVERCURRENT PROTECTION
- ⚠ F10 USED ON Y-VOLT UNITS ONLY
- ⚠ REFER TO INSTRUCTION SHEETS FOR LOW AMBIENT HARNESS INSTALLATION PROCEDURE

WARNING-ELECTRIC SHOCK HAZARD CAN CAUSE INJURY OR DEATH. UNIT MUST BE GROUNDED IN ACCORDANCE WITH NATIONAL AND LOCAL CODES

FOR USE WITH COPPER CONDUCTORS ONLY

DISCONNECT ALL POWER BEFORE SERVICING

IF ANY WIRE IN THIS APPLIANCE IS REPLACED, IT MUST BE REPLACED WITH WIRE OF LIKE SIZE, RATING, INSULATION THICKNESS AND TERMINATION


— DENOTES OPTIONAL COMPONENTS
 — LIVE VOLTAGE FIELD INSTALLED

2024/04		WIRING DIAGRAM	04/24
		538043-03	
COOLING - MSAV KG/KC C-BOX - 300S - G, J, Y VOLT LOW AMBIENT KIT			
SECTION B			REV. 2
Supersedes		New Form No.	
538043-02		538043-03	

Lennox Commercial

FIGURE 7

ICM333 (105240-01) TO ICM325A (105240-02) COMPARISON



ICM325A

ICM333

- 17% minimum voltage output setting in App ← CUT OUT SPEED to MIN, CCW turn (in the 'BALL BEARING RANGE')
- 48% minimum voltage output setting in App ← CUT OUT SPEED to MAX, CW turn (in the 'SLEEVE BEARING RANGE')
- ~0.5s LOWER hard start time in App ← HARD START to MIN, CCW turn (in the 'BALL BEARING RANGE')
- ~5s HIGHER hard start time in App ← HARD START to MAX, CW turn (in the 'SLEEVE BEARING RANGE')

FIGURE 8