

Job Name

Purchaser

Engineer

Submitted to

Reference

Approval

Construction

Unit Designation

Schedule #

Downflow kit(s) on this project

Model number	Description
VDK-1	Downflow kit, small chassis
VDK-2	Downflow kit, medium chassis
VDK-3	Downflow kit, large chassis

A downflow kit is required when airflow from the unit must blow downward.

Included in the kit: AHU coil door and return air temperature sensor holder. The original coil door can be discarded.

Compatibility

Model Number	VRF R-410A
VDK-1	VVCC012S4-4P ¹
	VVCC018S4-4P ¹
	VVCC024S4-4P ¹
VDK-2	VVCC030S4-4P ¹
	VVCC036S4-4P ¹
VDK-3	-
	VVCC048S4-4P
	VVCC054S4-4P
	VVCC060S4-4P
	VVCC072S4-4P

EEV extension wire harness shall be needed for noted models, and purchased separately.

Electric heat kits cannot be installed when using a downflow kit.

¹ Will require EEV extension wire harness, part number DB82-05832A, sold separately.

