

SUBMITTAL DATA – ACCESSORY M1HRDS01


R-32 LEAK DETECTOR ACCESSORY

Job: _____
 Location: _____
 Schedule No.: _____
 System Designation: _____


Engineer: _____
 Architect: _____
 Date: _____
 For: ☐ Reference ☐ Approval ☐ Review ☐ Construction

General Information:

- Accessory R32 leak detector for Mini-Split ducted units.
- When a leak is detected, the indoor unit will activate leak mitigation sequence of operations.
- Installs on the side of the ducted unit and plugs into the indoor unit control PCB (the indoor unit must be configured to for the leak detector to be enabled).



Front



Back

