

ADDENDUM

508934-01
08-11-2026

Addendum to Installation Instructions For Two-Stage 97% Efficiency Furnaces

Due to continuing improvements in the 110 k BTUh Input/Capacity furnace, the high altitude pressure switch has changed. This change affects both upflow/horizontal and downflow furnaces. See table 1 for the new kit numbers.

Table 1

LP/Propane Conversion Kit and Pressure Switch Requirements at Varying Altitudes

Two-Stage 97% Capacity	High Altitude Pressure Switch	
	4501 - 7500 ft	7501 - 10,000 ft
110	32L29	32L30



508934-01